

EU TYPE-EXAMINATION CERTIFICATE (MODULE B) REGULATION (EU) 2016/426

This is to certify that the appliances listed have been examined and found to comply with the essential requirements listed in the **Regulation (EU) 2016/426** of the European Parliament and of the council of 9 March 2016 on appliances burning gaseous fuels (Annex I).

To demonstrate full compliance with the Regulation (EU) 2016/426, a "Conformity to Type" Module C2 or D or E or F is required.

Applicant: Immergas S.p.A.
Via Cisa Ligure, 95, 42041 Brescello (RE) - Italy

Trade Mark: Immergas

Product Type: Central heating condensing combi boilers

Models: Victrix Zeus Superior 25
Victrix Zeus Superior 30
Victrix Zeus Superior 35

Certificate N°: ITS-2575-GAR-27620-R2

PIN: 2575DL27620

This certificate only relates to those products detailed in the following Test Reports:

Report Number: 200027620UDI-GCE-RCE-R2



Certificate Issue date:

01 March 2021

Certificate Expiry date:

16 December 2030

Sandro Zornio

Gas Certification Manager
Intertek Italia SpA (NB 2575)



PDR N° 277B

Membro degli Accordi di Mutuo
Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

PRODUCT DESCRIPTION

PRODUCT TYPE:	Central heating condensing combi boilers
MODELS:	Victrix Zeus Superior 25, Victrix Zeus Superior 30, Victrix Zeus Superior 35
STANDARD(S):	EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016
SPECIAL REMARKS:	-
APPLIANCES TYPE:	C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₆₃ , C ₈₃ , C ₉₃ , B _{23P} , B _{33P} , B _{53P} , C _{13X} , C _{33X} , C _{43X} , C _{53X} , C _{63X} , C _{83X} , C _{93X} , C ₍₁₀₎₃ [*] , C ₍₁₂₎₃ [*] , C ₍₁₅₎₃ [*] , C _{(10)3X} [*] , C _{(12)3X} [*] , C _{(15)3X} [*]
	(*) These appliance types are NOT available for 3P category (G31) C ₍₁₂₎₃ and C ₍₁₅₎₃ appliances types are listed in the EN 1749:2020

The gas categories for which the appliances have been tested can be obtained by combining the following countries and gas groups:

COUNTRIES:	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR
-------------------	--

GAS GROUP, REFERENCE GAS AND SUPPLY PRESSURES:

GROUP	REFERENCE GAS	GROUP	REFERENCE GAS	GROUP	REFERENCE GAS
H	G20 – 20 mbar	M	G230 – 20 mbar	P	G31 – 30 mbar
H	G20 – 25 mbar	Lw	G27 – 20 mbar	P	G31 – 37 mbar
E	G20 – 20 mbar	Ls	G2.350 – 13 mbar	P	G31 – 50 mbar
E(S)	G20 – 20 mbar				
E(R)	G20 – 20 mbar				

REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PRJ NO.	REPORT NO.	REASON FOR REVISION
17/12/2020	S. Zornio	27620	200027620UDI-GCE-RCE	R0: First issue
15/01/2021	S. Zornio	28171	200027620UDI-GCE-RCE-R1	R1: Introduction of the following gas group E(R), M, Lw and Ls
01/03/2021	S. Zornio	29279	200027620UDI-GCE-RCE-R2	R2: Introduction of C _{63x} Appliance Type.